


V74X Low HP

1. Part Number: CIMR-V7CUXXXX4-068
2. Applicable Models: 20P1 – 23P7, 40P2 – 43P7
3. Software Number: VSP018360
4. Modified PID Control Overview:



4. Additional Parameters:

Number	Description	Unit	Setting Range	Default Setting
n170	Set Point Selection	1	0 ~ 1	0
n171	PID Set Point Frequency	0.01 Hz (Note 1)	0.0 ~ 400.0 Hz (Note 2)	0.00 Hz

(Note 1) For values greater than 99.99 Hz, the decimal place will shift automatically (unit changes to 0.1 Hz).

(Note 2) Actual upper limit is based on Maximum Frequency (n011) setting.

5. Detailed Software Flowchart:

