



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

Yaskawa A1000, P1000, Z1000 VFDs

PROJECT: Yaskawa J1000 & V1000 Microdrives

REP: _____

ARCHITECT: --

ENGINEER: --

CUSTOMER: YASKAWA

P.O. NUMBER: 4200211053

COMMENTS:

Seismic Parameters:

Sds=2.0

Z/h =1.0

S/O NO.: 267486

DATE: 04/01/2015 VMA NO.: VMA-49850-1A

The VMC Group

Headquarters: 113 Main Street, Bloomingdale, NJ 07403 • Tel: 973-838-1780 • Fax: 973-492-8430

Houston: 11930 Brittmoore Park Dr Houston, TX 77041 • Tel: 713-466-0003 • Fax: 713-466-1355

www.thevmcgroup.com

REV.	DESCRIPTION	SOURCE of CHANGE	DATE
00	Initial Submittal	RJH	4/1/15

SEISMIC ANCHORAGE SUBMITTAL

CUSTOMER: YASKAWA

JOB: YASKAWA VFDS PHASE II OSP & IBCS

P.O. No: 4200211053

The following report has been performed for compliance with the applicable building codes and job specifications.

Applicable Building Code: **IBC 2006,2009,2012**

				 THE VMC GROUP <i>The Power of Together™</i>
	The VMC Group 113 Main St Bloomingdale, NJ 07403			
CAGE CODE 4U931		SIZE 	DWG NO VMA-49850-1A	
BY RJH		DATE: 4/1/2015	SO NO. 267486	REV 00
This report reflects information received and reviewed for seismic restraint as of date shown				



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A		REV. NO. 00	SHEET NO. 3 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED	DATE

Table of Contents:

Stamp Cover	2
Table of Contents	3-4
I Errors and Omissions Certificate	5
II. Schedule	6-7
III. Summary of Critical Assumptions and Directive Statements	8
IV. Purpose	8
V. Scope	8
VI. Strategy and Assumptions	9
VII. Allowable Loads	9
VIII. Seismic Input Forces	
i. ASD	10-11
ii. LRFD	12-13
IX. Analysis Methodology	14
X. Tags:	
i. UUT-8	
a. Wall Mounted Calculation ASD	16
b. Bolt Calculation	17
c. Anchorage Layout	18
d. Wall Mounted Calculation LRFD	19
e. Hilti Profis Report	20-21
f. Anchorage Layout – Concrete	22
ii. UUT-9	
a. Wall Mounted Calculation ASD	23
b. Bolt Calculation	24
c. Anchorage Layout	25
d. Wall Mounted Calculation LRFD	26
e. Hilti Profis Report	27-28
f. Anchorage Layout – Concrete	29



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT	JOB / DWG NUMBER	REV. NO.	SHEET NO.
Yaskawa VFDs Phase II OSP & IBCS	VMA-49850-1A	00	4 of 76
CUSTOMER	BY	DATE	CHECKED
Yaskawa	RJH	4/1/2015	

Table of Contents:

iii. UUT-10	
a. Floor Mounted Calculation ASD	30
b. Bolt Calculation	31
c. Anchorage Layout	32
d. Floor Mounted Calculation LRFD	33
e. Hilti Profis Report	34-35
f. Anchorage Layout – Concrete	36
iv. UUT-11	
a. Floor Mounted Calculation ASD	37
b. Bolt Calculation	38
c. Anchorage Layout	39
d. Floor Mounted Calculation LRFD	40
e. Hilti Profis Report	41-42
f. Anchorage Layout – Concrete	43
v. UUT-12	
a. Floor Mounted Calculation ASD	44
b. Bolt Calculation	45
c. Anchorage Layout	46
d. Floor Mounted Calculation LRFD	47
e. Hilti Profis Report	48-49
f. Anchorage Layout – Concrete	50
vi. UUT-13	
a. Floor Mounted Calculation ASD	51
b. Bolt Calculation	52
c. Anchorage Layout	53
d. Floor Mounted Calculation LRFD	54
e. Hilti Profis Report	55-56
f. Anchorage Layout – Concrete	57
vii. UUT-14	
a. Wall Mounted Calculation ASD	58
b. Attachment Calculation	59



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT	JOB / DWG NUMBER	REV. NO.	SHEET NO.
Yaskawa VFDs Phase II OSP & IBCS	VMA-49850-1A	00	5 of 76
CUSTOMER	BY	DATE	CHECKED
Yaskawa	RJH	4/1/2015	

Table of Contents:

viii. Microdrives -UUTs1&4	
a. Wall Mounted Calculation ASD	60
b. Attachment Calculation	61
ix. Microdrives -UUT2	
a. Wall Mounted Calculation ASD	62
b. Attachmnet Calculation	63
x. Microdrives -UUT3	
a. Wall Mounted Calculation ASD	64
b. Attachmnet Calculation	65
XI. Submittal Drawings	66-75
XII. Addendum	ICC-ES Report – ESR-2196



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
08/01/2014

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERNS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER Marsh USA, Inc. 1166 Avenue of the Americas New York, NY 10036 65465-Prof-S-14-15	CONTACT NAME: PHONE (A/C No. Ext): E-MAIL: ADDRESS:
	INSURER(S) AFFORDING COVERAGE INSURER A: Lloyd's Of London
INSURED The VMC Group 113 Main St. Bloomingdale, NJ 07403	INSURER B:
	INSURER C:
	INSURER D:
	INSURER E:
	INSURER F:

COVERAGES		CERTIFICATE NUMBER:		REVISION NUMBER: 6						
THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.										
INSR LTR	TYPE OF INSURANCE	ADDL INSR	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS			
GENERAL LIABILITY	GENERAL LIABILITY						EACH OCCURRENCE	\$		
	COMMERCIAL GENERAL LIABILITY						DAMAGE TO RENTED PREMISES (Ex occurrence)	\$		
	CLAIMS-MADE	OCCUR					MED EXP (Any one person)	\$		
							PERSONAL & ADV INJURY	\$		
							GENERAL AGGREGATE	\$		
							PRODUCTS - COMP/OP AGG	\$		
								\$		
GEN'L AGGREGATE LIMIT APPLIES PER:										
POLICY	PRO-JECT	LOC								
AUTOMOBILE LIABILITY	AUTOMOBILE LIABILITY						COMBINED SINGLE LIMIT (Ex accident)	\$		
	ANY AUTO						BODILY INJURY (Per person)	\$		
	ALL OWNED AUTOS	SCHEDULED AUTOS					BODILY INJURY (Per accident)	\$		
	Hired Autos	NON-OWNED AUTOS					PROPERTY DAMAGE (Per accident)	\$		
								\$		
		UMBRELLA LIAB	OCCUR							
		EXCESS LIAB	CLAIMS-MADE							
DED	RETENTION \$									
WORKERS COMPENSATION AND EMPLOYERS' LIABILITY						Y/N	N/A			
ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below						N			WC STATUTORY LIMITS	OTH-ER
								E.L. EACH ACCIDENT	\$	
								E.L. DISEASE - EA EMPLOYEE	\$	
								E.L. DISEASE - POLICY LIMIT	\$	
A	Manufacturers Engineering			B0621PVMC00114	08/01/2014	07/01/2015	Limit	3,000,000		
A	Design Errors & Omissions			B0621PVMC00114	08/01/2014	07/01/2015	Limit	3,000,000		
DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (Attach ACORD 101, Additional Remarks Schedule, if more space is required)										
Evidence of Coverage										

CERTIFICATE HOLDER

The VMC Group 113 Main St. Bloomingdale, NJ 07403	CANCELLATION	
	SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS.	
AUTHORIZED REPRESENTATIVE of Marsh USA Inc. Chris Gannon		

© 1988-2010 ACORD CORPORATION. All rights reserved.

Table 1: Schedule

Item #	Page #	Attachment System														
		Tag	Sds	Qty.	Mfr.	Model	I _P	z/h	Attachment Method	Equipment Weight (#)	Isolation System	Seismic Restraint	Qty. Per Tag	Model	Qty. Per Tag	
1	16-21	UUT-8	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	150	--	None	--	As Per Anchor Calculation	4	3/8" dia SAE Grade 8/ ASTM A490 Bolts
2	23-29	UUT-9	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Concrete)	550	--	None	--	As Per Anchor Calculation	4	3/8" dia SAE Grade 8/ ASTM A490 Bolts
3	30-36	UUT-10	2	1	Yaskawa	N/A	1.5	1.0	Floor Mounted (Steel)	850	--	None	--	As Per Anchor Calculation	6	1/2" dia SAE Grade 8/ ASTM A490 Bolts
4	37-43	UUT-11	2	1	Yaskawa	N/A	1.5	1.0	Floor Mounted (Concrete)	950	--	None	--	As Per Anchor Calculation	4	1/2" dia SAE Grade 8/ ASTM A490 Bolts
									Floor Mounted (Steel)							1/2" Dia. Hilti Kwik Bolt TZ-CS with min. embedment 2"; edge distance of 4" on a 4" thick 4000 Psi Concrete Wall
									Floor Mounted (Concrete)							1/2" Dia. Hilti Kwik Bolt TZ-CS with min. embedment 3.25"; edge distance of 6" on a 6" thick 4000 Psi Concrete Wall

		JOB: Yaskawa VFDs Phase II OSP & IBCS					
		S.O No.: 267486					
		CUSTOMER: Yaskawa					
Rev	By	Initial Submission	4/1/15	By	RJH	Date	RJH
00		Description		Checked		Date	4/1/2015
						DWG. NO.	VMA-49850-1A
						PAGE	7 OF 76


Table 1: Schedule

Item #	Page #	Tag	Sds	Qty	Mfr.	Model	I_p	z/h	Attachment Method	Equipment Weight (#)	Isolation System	Seismic Restraint	Attachment System
										Qty. Per Tag	Model	Qty. Per Tag	
5	44-50	UUT-12	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	2100	--	None	4
									Wall Mounted (Concrete)			As Per Anchor Calculation	1/2" dia SAE Grade 8/ ASTM A490 Bolts
6	51-57	UUT-13	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	2200	--	None	4
									Wall Mounted (Concrete)			As Per Anchor Calculation	1/2" Dia. Hilti TZ-CS with min. embedment 3.25"; edge distance of 6" on a 6" thick 4000 Psi Concrete Wall
7	58-59	UUT-14	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	70	--	None	4
												As Per Anchor Calculation	1/4" dia Screws
8	60-61	UUTS 1 & 4	2	2	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	5.3	--	None	4
												As Per Anchor Calculation	#8 Screws
9	62-63	UUT2	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	6.6	--	None	4
												As Per Anchor Calculation	#8 Screws
10	64-65	UUT3	2	1	Yaskawa	N/A	1.5	1.0	Wall Mounted (Steel)	20.2	--	None	4
												As Per Anchor Calculation	1/4" dia Screws

JOB: Yaskawa VFDs Phase II OSP & IBCS

S.O. No.: 267486

CUSTOMER: Yaskawa



The VMC Group
Bloomingdale, NJ
07403



The VMC Group
Bloomingdale, NJ
07403

Rev By	Description	Date	By	Date	Checked	Date	DWG. NO.	PAGE
00	RJH	Initial Submission	4/1/15	RJH	4/1/2015		VMA-49850-1A	8 OF 76



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 9 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

III. SUMMARY OF CRITICAL ASSUMPTIONS AND DIRECTIVE STATEMENTS:

1. This analysis does not certify that the concrete housekeeping pads, building structure, isolated or restrained equipment, or any other attached equipment, such as piping or ductwork, is capable of handling the applied seismic loads. Any non-VMC Group mounting supports, brackets, or other means of attachment must be independently certified. This calculation only certifies the seismic restraint capability of the VMC Group supplied mounting equipment and the attachment of the equipment.
2. Weight and dimensional data was provided by the customer. Information not provided for in the job specification must be verified by the building engineer. The values used in this analysis should be verified. If they vary, disregard these recommendations and notify The VMC Group of the changes.
3. All accessory attachments (pipe, conduit, etc.) to the equipment shall be attached in a manner that allows relative motion (flex, swing joint/elbow, etc.) to prevent failure due to differential movement between the equipment and attached accessory caused by seismic loading on the system.
4. Unless noted on the drawings, all drawings in this report are considered not to scale.
5. All housekeeping pads must be properly dowelled and reinforced by others to carry the seismic loads.
6. When several pieces of equipment are installed identically, the most critical one is analyzed.
7. When installing concrete expansion anchors, the anchors shall be torqued to manufacturer recommended settings to ensure maximum holding capacity in the concrete. Observe concrete edge distance and anchor spacing limitations as expressed by the anchor manufacturer or ICC-ES rating publication. For anchors installed in the underside of the slab, embedment depth must be at least one half of the slab thickness to ensure the anchor is embedded in the compression zone of the slab.
8. If isolators are supplied by The VMC Group it has been assumed that the structure supporting the isolators has a stiffness ten (10) times that of the isolator or three (3) times the natural frequency of the isolators. The equipment itself and any steel structure between the equipment and the isolators are considered rigid for calculation purposes.

IV. PURPOSE:

This report is submitted to Yaskawa for the Yaskawa VFDs Phase II OSP & IBCS project to verify that the seismic/wind restraints provided and/or recommended by The VMC Group will safely accept loads applied from seismic forces and normal operating loads. For equipment isolated by The VMC Group, this report verifies adequate isolation per the job specification.

V. SCOPE:

This report covers only seismic restraints, isolators, and engineering recommendations provided by The VMC Group for use as listed in Table I.

This report does not cover equipment supplied by other vendors. The structural design professional must verify the adequacy of the superstructure or substructure to which The VMC Group components or specified hardware are attached. The structure must withstand the seismic loads applied at restraint locations.

The following report has been performed for compliance with the applicable building codes and job specification. If there are any specifications or information that supersede the assumptions made herein, this analysis may be invalid, and The VMC Group must be notified for review of changes.



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT	JOB / DWG NUMBER	REV. NO.	SHEET NO.
Yaskawa VFDs Phase II OSP & IBCS	VMA-49850-1A	00	10 of 76
CUSTOMER	BY	DATE	CHECKED DATE
Yaskawa	RJH	4/1/2015	

VI. STRATEGY AND ASSUMPTIONS:

For the purposes of this analysis, it must be assumed that the building and its internal structure have been designed to perform as required by the adopted building code in response to an earthquake and remain intact and functioning after such an event. Per code the equipment must be restrained and not break away from its supports during an earthquake. The forces acting on a piece of equipment are the vertical and lateral forces resulting from the earthquake, the force of gravity, and the forces at the restraints that hold the equipment in place. The analysis assumes that the equipment does not move beyond the restraints during the earthquake. The acceleration at its center of gravity generate forces that must be balanced by reactions at the restraints. The code allows equipment to be analyzed as though it were a rigid component; however, factors (a_p , R_p) are applied within the computation to address flexibility issues for particular equipment types or flexible mounting arrangements. Given the above, the problem can be reduced to a static analysis.

The forces acting on the restraints include both shear and tensile components. The application direction of the lateral seismic acceleration can vary and is unknown. Depending on its direction, it is likely that not all of the restraints will be affected or share the load equally. This report will determine the worst case combination of forces at all restraint points for any possible direction that the acceleration can follow to ensure that the restraints are adequate.

It is assumed that the equipment is designed to be strong enough to transfer the load from its center of gravity to the restraint connection points without failure. Under some instances (particularly those relating to life support issues in hospital settings) code requirements indicate that critical equipment must be seismically qualified to ensure its continued operation after a seismic event. Special care must be taken in these situations to ensure that the equipment has been certified to meet the maximum anticipated seismic load.

VII. ALLOWABLE LOADS:

Unless otherwise specified, allowable bolt loads are per the Manual of Steel Construction - AISC 13th Edition. All concrete is assumed to be 4000 psi.

For The VMC Group products: Ratings are per test and/or analysis.

For Concrete Anchors: Ratings are per ICC ESR reports or Hilti Profis



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 11 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

VIII-a-i.SEISMIC INPUT FORCES - ASD

These calculations certify that the VMC components and specified hardware, when properly installed, are capable of safely supporting a maximum seismic load based upon the ASD load combinations from ASCE – 7-05 :

$$\begin{aligned} E &= 1.0D(+/-) 0.7E \\ &= 0.6D(+/-) 0.7E \end{aligned}$$

Where:

$$E = pQ_E(+/-).2S_{DS}D$$

p= Reliability factor: taken as 1.0 for mechanical and electrical components

Q_E = horizontal seismic force F_p

S_{DS}= Design spectral response

D= Dead load

(0.2S_{DS}D is taken in the vertical direction)

Final Seismic Loading Conditions:

1: Vertical Load (P_z) = (1.0 + 0.7*0.2*S_{DS})

Horizontal Load (P_h) = 0.7*F_p

2: Vertical Load (P_z) = (0.6 - 0.7*0.2*S_{DS})

Horizontal Load (P_h) = 0.7*F_p

Horizontal Seismic Force per equation 13.3-1 (ASCE 7):

$$F_p = \frac{0.4 * a_p * S_{DS} * (1+2(z/h))}{(R_p/I_p)} * W_p$$

Where:

a_p = The attachment amplification factor

S_{DS} = Design Spectral Response Acc. at short period

S_{MS} = Max Earthquake Spectral Response Acc. for Short Period

F_a = Site Coefficient (Use "D" if unknown)

S_s = Mapped Spectral Acc. for Short Period

z = Height of the equipment attachment to structure.

h = Average Roof Height

R_p = Component Response Modification factor

I_p = Component Importance factor

W_p = The operating weight of the system

And:

$$S_{DS} = (2/3)*S_{MS}$$

$$S_{MS} = F_a * S_s$$



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 12 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

VIII-a-ii. SEISMIC INPUT FORCES: (ASD for use with Steel Anchor Calculation)

The building is an Occupancy Category IV $S_s = 3.00$

Site class = D

Therefore use Seismic Design Category D

From the appropriate tables:

$F_a = 1.00$

$S_{ds} = 2.0$

For:	$a_p = 2.5$	$a_p = 2.5$	$a_p = 2.5$	$a_p = 2.5$
At:	$R_p = 6$	$R_p = 2$	$R_p = 6$	$R_p = 2$
	$I_p = 1.5$	$I_p = 1.5$	$I_p = 1.5$	$I_p = 1$
z/h =				
0.0	0.50 g's	0.0	1.50 g's	0.0
0.2	0.70 g's	0.2	2.10 g's	0.2
0.4	0.90 g's	0.4	2.70 g's	0.4
0.6	1.10 g's	0.6	3.30 g's	0.6
0.8	1.30 g's	0.8	3.90 g's	0.8
1.0	1.50 g's	1.0	4.50 g's	1.0

Satisfying the upper and lower bounds:

$0.3 \times S_{ds} \times I_p \times W_p < F_p < 1.6 \times S_{ds} \times I_p \times W_p$

At $I_p = 1.5$, F_p Min = 0.90 g's


At $I_p = 1.5$, F_p Max = 4.80 g's

At $I_p = 1$, F_p Min = 0.60 g's

At $I_p = 1$, F_p Max = 3.20 g's

Table 2

Condition	At z/h =	P_h		P_z		P_h		P_z	
		Ph	Pz	Ph	Pz	Ph	Pz	Ph	Pz
Condition 1	0.0	0.63 g's	1.28 g's	1.05 g's	1.28 g's	0.63 g's	1.28 g's	0.70 g's	1.28 g's
	0.2	0.63 g's	1.28 g's	1.47 g's	1.28 g's	0.63 g's	1.28 g's	0.98 g's	1.28 g's
	0.4	0.63 g's	1.28 g's	1.89 g's	1.28 g's	0.63 g's	1.28 g's	1.26 g's	1.28 g's
	0.6	0.77 g's	1.28 g's	2.31 g's	1.28 g's	0.77 g's	1.28 g's	1.54 g's	1.28 g's
	0.8	0.91 g's	1.28 g's	2.73 g's	1.28 g's	0.91 g's	1.28 g's	1.82 g's	1.28 g's
	1.0	1.05 g's	1.28 g's	3.15 g's	1.28 g's	1.05 g's	1.28 g's	2.10 g's	1.28 g's
Condition 2	0.0	0.63 g's	0.32 g's	1.05 g's	0.32 g's	0.63 g's	0.32 g's	0.70 g's	0.32 g's
	0.2	0.63 g's	0.32 g's	1.47 g's	0.32 g's	0.63 g's	0.32 g's	0.98 g's	0.32 g's
	0.4	0.63 g's	0.32 g's	1.89 g's	0.32 g's	0.63 g's	0.32 g's	1.26 g's	0.32 g's
	0.6	0.77 g's	0.32 g's	2.31 g's	0.32 g's	0.77 g's	0.32 g's	1.54 g's	0.32 g's
	0.8	0.91 g's	0.32 g's	2.73 g's	0.32 g's	0.91 g's	0.32 g's	1.82 g's	0.32 g's
	1.0	1.05 g's	0.32 g's	3.15 g's	0.32 g's	1.05 g's	0.32 g's	2.10 g's	0.32 g's





THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 13 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

VIII-b-i. SEISMIC INPUT FORCES-LRFD

These calculations certify that the VMC components and specified hardware, when properly installed, are capable of safely supporting a maximum seismic load based upon the LRFD load combinations from the building code or ASCE-7-05:

$$\begin{aligned} & 1.2D(+/-) 1.0E \\ & 0.9D(+/-) 1.0E \end{aligned}$$

Where:

$$E = \rho Q_E (+/-) 0.2 S_{DS} D$$

ρ = Reliability factor: taken as 1.0 for mechanical and electrical components

Q_E = horizontal seismic force F_p

S_{DS} = Design spectral response

D = Dead load

($0.2 S_{DS} D$ is taken in the vertical direction)

Final Seismic Loading Conditions:

$$1: \text{Vertical Load (Pz)} = (1.2 + 1.0 * 0.2 * S_{DS})$$

$$\text{Horizontal Load (Px)} = 1.0 * F_p$$

$$2: \text{Vertical Load (Pz)} = (0.9 - 1.0 * 0.2 * S_{DS})$$

$$\text{Horizontal Load (Px)} = 1.0 * F_p$$

Horizontal Seismic Force per equation 13.3-1 (ASCE-7):

$$F_p = \frac{0.4 * a_p * S_{DS} * (1 + 2(z/h)) * W_p}{(R_p/I_p)}$$

Where:

a_p = The attachment amplification factor

S_{DS} = Design Spectral Response Acc. at short period

S_{MS} = Max Earthquake Spectral Response Acc. for Short Period

F_a = Site Coefficient (Use "D" if unknown)

S_s = Mapped Spectral Acc. for Short Period

z = Height of the equipment attachment to structure.

h = Average Roof Height

R_p = Component Response Modification factor

I_p = Component Importance factor

W_p = The operating weight of the system

And:

$$S_{DS} = (2/3) * S_{MS}$$

$$S_{MS} = F_a * S_s$$



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 14 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

VIII-b-ii. SEISMIC INPUT FORCES: (LRFD for use with Concrete Anchor Calculation)

The building is an Occupancy Category IV $S_s = 3.00$

Site class = D

Therefore use Seismic Design Category D

From the appropriate tables:

$F_a = 1.00$

$S_{ds} = 2.00$

For:	$a_p = 2.5$	$a_p = 2.5$	$a_p = 1.0$	$a_p = 1.0$
At:	$R_p = 6$	$R_p = 6$	$R_p = 2.5$	$R_p = 2.5$
	$I_p = 1.5$	$I_p = 1.5$	$I_p = 1.5$	$I_p = 1$
z/h =	Fp =	z/h =	Fp =	z/h =
0.0	0.50 g's	0.0	0.50 g's	0.0
0.2	0.70 g's	0.2	0.70 g's	0.2
0.4	0.90 g's	0.4	0.90 g's	0.4
0.6	1.10 g's	0.6	1.10 g's	0.6
0.8	1.30 g's	0.8	1.30 g's	0.8
1.0	1.50 g's	1.0	1.50 g's	1.0


Satisfying the upper and lower bounds:
 $0.3 \cdot S_{ds} \cdot I_p \cdot W_p < F_p < 1.6 \cdot S_{ds} \cdot I_p \cdot W_p$

At $I_p = 1.5$, F_p Min = 0.90 g's

At $I_p = 1.5$, F_p Max = 4.80 g's

Table 2

Condition	1	At z/h =	Ph	Pz	Ph	Pz	Ph	Pz
			0.90 g's	1.60 g's	0.90 g's	1.60 g's	0.90 g's	1.60 g's
Condition 1		0.0	0.90 g's	1.60 g's	0.90 g's	1.60 g's	0.90 g's	1.60 g's
		0.2	0.90 g's	1.60 g's	0.90 g's	1.60 g's	0.90 g's	1.60 g's
		0.4	0.90 g's	1.60 g's	0.90 g's	1.60 g's	0.90 g's	1.60 g's
		0.6	1.10 g's	1.60 g's	1.10 g's	1.60 g's	1.06 g's	1.60 g's
		0.8	1.30 g's	1.60 g's	1.30 g's	1.60 g's	1.25 g's	1.60 g's
		1.0	1.50 g's	1.60 g's	1.50 g's	1.60 g's	1.44 g's	1.60 g's
Condition 2		0.0	0.90 g's	0.50 g's	0.90 g's	0.50 g's	0.90 g's	0.50 g's
		0.2	0.90 g's	0.50 g's	0.90 g's	0.50 g's	0.90 g's	0.50 g's
		0.4	0.90 g's	0.50 g's	0.90 g's	0.50 g's	0.90 g's	0.50 g's
		0.6	1.10 g's	0.50 g's	1.10 g's	0.50 g's	1.06 g's	0.50 g's
		0.8	1.30 g's	0.50 g's	1.30 g's	0.50 g's	1.25 g's	0.50 g's
		1.0	1.50 g's	0.50 g's	1.50 g's	0.50 g's	1.44 g's	0.50 g's








THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls


PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 15 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

IX. ANALYSIS METHODOLOGY

These calculations follow a similar procedure as set out in ASHRAE Applications Chapter 54. Moments are taken about the center of restraints to create a free-body diagram of the restrained equipment, which is assumed to be rigid. This yields the maximum reaction loads. The calculation spreadsheet that follows uses these dimensions shown here.



End Elevation



Side Elevation



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 16 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

Equipment Tag			
UUT-8 on steel structure			
X-i-a. Seismic Restraint Load Calculation		Load Combinations are as per ASD	
Mfr	Yaskawa	Model	N/A
Input Values			
Coefficient	Value	Units	Description
X	21.4	in	Equipment Depth
Y	15.5	in	Distance Between Attachment Points Along Unit Width
Z	27.34	in	Distance Between Attachment Points Along Unit Height
m	150	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	10.7	in	Center of Gravity Along Depth Direction
Y _{cg}	7.75	in	Center of Gravity Along Width Direction
Z _{cg}	13.67	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	27	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$


$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T_{max} 104 lbs


V_{max} 59 lbs



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 17 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-i-b.Check Bolting of Equipment to Structural steel

Tag: UUT-8

Bolting using 3/8" diameter SAE Grade 5/ ASTM A325 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.375	0.110 in^2	104 #	59 #	0.94 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel Structure

Stress Area = 0.110 in^2

Design Tension Stress of the Bolt = 104 # / 0.110 in^2 = 0.94 ksi

Design Shear Stress of the Bolt = 59 # / 0.110 in^2 = 0.53 ksi

F_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksiF_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksif_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

Applying the equation above to find the allowable tension stress at this shear;

$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 3/8" diameter A325 bolt is sufficient for this application ✓


TAG: UUT-08

21.40

15.50

Φ Φ

27.34



(4) 3/8" Ø SAE GRADE 8 /
ASTM A325 BOLTS

Note:
1) All Dimensions are in Inches
2) See Yaskawa dwg# DD.Z1.3R.W1.01
for details.

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-08 STEEL ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

18 OF 76

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

MEMBER

VISCAM

DRAWING NO.:

VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 19 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE


Equipment Tag			
UUT-8 mounted on concrete wall			
X-i-d. Seismic Restraint Load Calculation		Load Combinations are as per LRFD	
Mfr	Yaskawa	Model	N/A
Input Values			
Coefficient	Value	Units	Description
X	21.4	in	Equipment Depth
Y	15.5	in	Distance Between Attachment Points Along Unit Width
Z	27.34	in	Distance Between Attachment Points Along Unit Height
m	150	lbs	Equipment Mass
g _h	1.5	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.6	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	10.7	in	Center of Gravity Along Depth Direction
Y _{cg}	7.75	in	Center of Gravity Along Width Direction
Z _{cg}	13.67	in	Center of Gravity Along Height Direction

Critical Angle			
Coefficient	Value	Units	Description
φ	24	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi) \quad mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y|/2)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$



Equipment is attached to wall with (4)3/8" Dia. Hilti Kwik Bolt TZ-CS with min. embedment 2"; edge distance of 3" on a 3" thick 4000 Psi Concrete wall

Specifier's comments:**1 Input data**

Anchor type and diameter:	Kwik Bolt TZ - CS 3/8 (2)
Effective embedment depth:	$h_{ef,act} = 2.000 \text{ in.}, h_{nom} = 2.313 \text{ in.}$
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued / Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318-11 / Mech.
Stand-off installation:	$e_b = 0.000 \text{ in.}$ (no stand-off); $t = 0.375 \text{ in.}$
Anchor plate:	$l_x \times l_y \times t = 2.000 \text{ in.} \times 2.000 \text{ in.} \times 0.375 \text{ in.}$; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f_c' = 4000 \text{ psi}$; $h = 4.000 \text{ in.}$
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))

**Geometry [in.] & Loading [lb, in.lb]**

Company:
Specifier:
Address:
Phone / Fax:
E-Mail:

Page:
Project:
Sub-Project / Pos. No.:
Date:
4/1/2015

21


2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Pullout Strength	282	1400	21 / -	OK
Shear	Concrete edge failure in direction x+	142	1299	- / 11	OK
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V} [\%]$
Combined tension and shear loads		0.201	0.109	5/3	10


Fastening meets the design criteria!

21.40

TAG: UUT-08
15.50



27.34



Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.3R.W1.01 for details.

CERTIFIED FOR:


JOB NAME: Baseline VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-08 CONCRETE ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

22 OF 76

VISCAM
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

MEMBER

VMCA

REVISION

A

VMCA-49850 01A



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 23 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

Equipment Tag			
UUT-9 on steel structure			
X-i-a. Seismic Restraint Load Calculation		Load Combinations are as per ASD	
Mfr	Yaskawa	Model	N/A
Input Values			
Coefficient	Value	Units	Description
X	21.47	in	Equipment Depth
Y	30.06	in	Distance Between Attachment Points Along Unit Width
Z	49.32	in	Distance Between Attachment Points Along Unit Height
m	550	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	10.735	in	Center of Gravity Along Depth Direction
Y _{cg}	15.03	in	Center of Gravity Along Width Direction
Z _{cg}	24.66	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	39	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$

$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T_{max}


248 lbs

V_{max}


209 lbs



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 24 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-ii-b.Check Bolting of Equipment to Structural steel

Tag: UUT-9

Bolting using 3/8" diameter SAE Grade 5/ ASTM A325 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.375	0.110 in ²	248 #	209 #	2.25 ksi
					1.89 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel StructureStress Area = 0.110 in²Design Tension Stress of the Bolt = 248 # / 0.110 in² = 2.25 ksiDesign Shear Stress of the Bolt = 209 # / 0.110 in² = 1.89 ksiF_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksiF_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksif_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

Applying the equation above to find the allowable tension stress at this shear;

$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 3/8" diameter A325 bolt is sufficient for this application ✓



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 26 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE


Equipment Tag			
UUT-9 mounted on concrete wall			
X-ii-d. Seismic Restraint Load Calculation		Load Combinations are as per LRFD	
Mfr Yaskawa		Model N/A	
Input Values			
Coefficient	Value	Units	Description
X	21.47	in	Equipment Depth
Y	30.06	in	Distance Between Attachment Points Along Unit Width
Z	49.32	in	Distance Between Attachment Points Along Unit Height
m	550	lbs	Equipment Mass
g _h	1.5	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.6	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	10.735	in	Center of Gravity Along Depth Direction
Y _{cg}	15.03	in	Center of Gravity Along Width Direction
Z _{cg}	24.66	in	Center of Gravity Along Height Direction

Critical Angle			
Coefficient	Value	Units	Description
φ	37	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi) \quad mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(Y_{cg} - Y/2)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$



Equipment is attached to wall with (4)3/8" Dia. Hilti Kwik Bolt TZ-CS with min. embedment 2"; edge distance of 3" on a 3" thick 4000 Psi Concrete wall

Specifier's comments:**1 Input data**

Anchor type and diameter:	Kwik Bolt TZ - CS 1/2 (2)
Effective embedment depth:	$h_{ef,act} = 2.000 \text{ in.}$, $h_{nom} = 2.375 \text{ in.}$
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318-11 / Mech.
Stand-off installation:	$e_b = 0.000 \text{ in.}$ (no stand-off); $t = 0.375 \text{ in.}$
Anchor plate:	$l_x \times l_y \times t = 2.000 \text{ in.} \times 2.000 \text{ in.} \times 0.375 \text{ in.}$; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f_c' = 4000 \text{ psi}$; $h = 4.000 \text{ in.}$
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))

**Geometry [in.] & Loading [lb, in.lb]**

Company:
Specifier:
Address:
Phone / Fax:
E-Mail:




Page: 35
Project:
Sub-Project / Pos. No.:
Date: 4/1/2015

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Concrete Breakout Strength	967	1483	66 / -	OK
Shear	Concrete edge failure in direction x+	223	1417	- / 16	OK
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V} [\%]$
Combined tension and shear loads		0.652	0.157	5/3	54

Fastening meets the design criteria!

TAG: UUT-09



(4) 3/8" Ø HILTI KWIK BOLT TZ-CS

MIN. 2" EMBEDMENT

4" EDGE DISTANCE

4000 PSI CONCRETE

W/ 4" THICK.

Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.3R.W4.01 for details.

CERTIFIED FOR:


JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-09 CONCRETE ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

29 OF 76

Member
VISCHER

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.:

VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 30 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-iii-a. Seismic Force Calculation: UUT-10

LRFD

ASD

AC-156

Ss =	3.00	ap =	2.5	From the tables:				
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual
Site Class	D	Ip =	1.5	S _{DS} =	2.000	F _p /W _p =	0.90 g's	1.50 g's
Occupancy Category	IV	Calculated Seismic Design Category		D			DL	E
Mfr	Yaskawa	Model	N/A			Load Combination 1	1	
						Load Combination 2	0.6	0.7

Calculate the maximum loading at the most critical anchor location.

Principal Axis Calculation

Input Data						Calculated Loads		
W	horz g's	vert g's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min
850 #	1.050	0.320	1.280	40.14"	17.95"	14.58"	893 #	1088 #
Restraint Locations		ly1	Ix1	Ixy	J1	Oversetting Loads (F _p Only)	Rigid Weight Distribution	Seismic Vertical Distribution
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert
1	1.00"	1.00"	319	196	250	515	722 #	155 #
2	1.00"	15.00"	319	0	0	319	155 #	149 #
3	1.00"	29.00"	319	196	-250	515	-412 #	143 #
4	36.73"	1.00"	319	196	-250	515	412 #	141 #
5	36.73"	15.00"	319	0	0	319	-155 #	134 #
6	36.73"	29.00"	319	196	250	515	-722 #	128 #
Center of Restraints		ly total 18.9"	Ix total 15.0"	Ixy total 1915	J total 784	0 #	850 #	1088
					2699		0	272
							0	0
Cx 17.9"	Cy 14.0"	# Vertical Restraints 6	# Horizontal Restraints 6	Theta 207.6 deg		Tanθ 0.481 rad	r max 0.522	r max 22.7"
Max Loads per Location								
F _p Only	-31753	-16589	-6.08E+07	-1.30E+07	1.50E+06	Comp (Max Vert)	921 #	
					Mz	Tens. (Min Vert)	681 #	
Static Vert	-357	-778	-6.84E+05	-6.10E+05	899	Shear	156 #	



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 31 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-iii-b. Check Bolting of Equipment to Structural steel

Tag: UUT-10

Bolting using 1/2" diameter SAE Grade 8/ ASTM A490 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.500	0.196 in^2	681 #	156 #	3.47 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel Structure

Stress Area = 0.196 in^2

Design Tension Stress of the Bolt = 681 # / 0.196 in^2 = 3.47 ksi

Design Shear Stress of the Bolt = 156 # / 0.196 in^2 = 0.79 ksi

F_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksiF_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksif_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

Applying the equation above to find the allowable tension stress at this shear;




$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 1/2" diameter A325 bolt is sufficient for this application



TAG: UUT-10



(6) 1/2" Ø SAE GRADE 8 /
ASTM A490 BOLTS

Note:
1) All Dimensions are in Inches
2) See Yaskawa dwg# DD.Z1.3R.F1.02
for details.

3) See Yaskawa dwg # USP03233 for
mounting foot details

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-10 STEEL ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

32 OF 76

VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

MEMBER

WESCAM

DRAWING NO.:

VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 33 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED AC-156

X-iii-d. Seismic Force Calculation: UUT-10

LRFD ASD AC-156

Ss =	3.00	ap =	2.5	From the tables:				
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	4.80 g's
Occupancy Category	IV	Calculated Seismic Design Category		D			DL	E
Mfr	Yaskawa	Model	N/A			Load Combination 1	1.2	1
Calculate the maximum loading at the most critical anchor location.								
Load Combination 2 0.9								

Principal Axis Calculation

Input Data						Calculated Loads		
W	horz g's	vert g's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min
850 #	1.500	0.500	1.600	40.14"	17.95"	14.58"	1275 #	1360 #
Restraint Locations		ly1	lx1	lxy	J1	Oversetting Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert Min Vert
1	1.00"	1.00"	319	196	250	515	1031 #	155 #
2	1.00"	15.00"	319	0	0	319	221 #	149 #
3	1.00"	29.00"	319	196	-250	515	-589 #	143 #
4	36.73"	1.00"	319	196	-250	515	589 #	141 #
5	36.73"	15.00"	319	0	0	319	-221 #	134 #
6	36.73"	29.00"	319	196	250	515	-1031 #	128 #
Center of Restraints		ly total	lx total	lxy total	J total	0 #	850 #	1360
18.9"	15.0"	1915	784	0	2699		0	0
Cx 17.9"	Cy 14.0"	# Vertical Restraints 6	# Horizontal Restraints 6		Theta 207.6 deg	Tanθ 0.481 rad	r max 0.522	22.7"
	Mx	My	Mxly-Mylx	Mylx-Mxly	lxly-lxy ²	Max Loads per Location		
Fp Only	-45361	-23698	-8.69E+07	-1.86E+07	1.50E+06	Comp (Max Vert)	1280 #	
					Mz	Tens. (Min Vert)	967 #	
Static Vert	-357	-778	-6.84E+05	-6.10E+05	1284	Shear	223 #	

Design Tension =

967#

Design Shear =

223#


Equipment is attached to concrete with (4) Hilti Kwik Bolt TZ-CS, 1/2" Dia. with 3.25" min. embedment

Edge distance of 6" on a 6" thick concrete pad of 4000Psi

Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ - CS 1/2 (2)
Effective embedment depth:	$h_{ef,act} = 2.000 \text{ in.}$, $h_{nom} = 2.375 \text{ in.}$
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318-11 / Mech.
Stand-off installation:	$e_b = 0.000 \text{ in.}$ (no stand-off); $t = 0.375 \text{ in.}$
Anchor plate:	$l_x \times l_y \times t = 2.000 \text{ in.} \times 2.000 \text{ in.} \times 0.375 \text{ in.}$; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f_c' = 4000 \text{ psi}$; $h = 4.000 \text{ in.}$
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))


Geometry [in.] & Loading [lb, in.lb]


Company:
Specifier:
Address:
Phone / Fax:
E-Mail:



Page: 35
Project:
Sub-Project / Pos. No.:
Date: 4/1/2015

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Concrete Breakout Strength	967	1483	66 / -	OK
Shear	Concrete edge failure in direction x+	223	1417	- / 16	OK
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V} [\%]$
Combined tension and shear loads		0.652	0.157	5/3	54

Fastening meets the design criteria!

TAG: UUT-10



Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.3R.F1.02 for details.
- 3) See Yaskawa dwg # USP03233 for mounting foot details

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-10 CONCRETE ANCHORAGE LAYOUT



SCALE:
NONE
SHEET:
36 OF 76

VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION

MEMBER
VISCAM



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 37 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-iv-a. Seismic Force Calculation: UUT-11

LRFD

ASD

AC-156

Ss =	3.00	ap =	2.5	From the tables:						
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual		
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	4.80 g's		
Occupancy Category	IV	Calculated Seismic Design Category			D	DL E				
Mfr	Yaskawa	Model	N/A	Load Combination 1		1	0.7			
Calculate the maximum loading at the most critical anchor location.										
Principal Axis Calculation										
Input Data						Calculated Loads				
W	horz g's	vert g's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min		
850 #	1.050	0.320	1.280	40.14"	17.95"	14.58"	893 #	1088 #	272 #	
Restraint Locations		ly1	Ix1	Ixy	J1	Overswinging Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution		
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert	Min Vert	
1	1.00"	1.00"	319	196	250	515	722 #	155 #	921	771
2	1.00"	15.00"	319	0	0	319	155 #	149 #	345	202
3	1.00"	29.00"	319	196	-250	515	-412 #	143 #	-230	-367
4	36.73"	1.00"	319	196	-250	515	412 #	141 #	592	457
5	36.73"	15.00"	319	0	0	319	-155 #	134 #	17	-112
6	36.73"	29.00"	319	196	250	515	-722 #	128 #	-558	-681
Center of Restraints		ly total 18.9"	Ix total 15.0"	Ixy total 1915	J total 784	0 # 2699	850 # 0	1088 # 0	272 # 0	
Cx	Cy	# Vertical Restraints	# Horizontal Restraints	Theta 207.6 deg			Tanθ 0.481 rad	r max 0.522		
17.9"	14.0"	6	6	0.481 rad	207.6 deg		0.522	22.7"		
	Mx	My	Mxly-MyIxy	MyIx-MxIxy	Ixly-Ixy ²	Max Loads per Location				
Fp Only	-31753	-16589	-6.08E+07	-1.30E+07	1.50E+06	Comp (Max Vert)	921 #			
					Mz	Tens. (Min Vert)	681 #			
Static Vert	-357	-778	-6.84E+05	-6.10E+05	899	Shear	156 #			



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 38 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-iv-b. Check Bolting of Equipment to Structural steel

Tag: UUT-11

Bolting using 1/2" diameter SAE Grade 8/ ASTM A490 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.500	0.196 in ²	681 #	156 #	3.47 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel Structure

Stress Area = 0.196 in²

Design Tension Stress of the Bolt = 681 # / 0.196 in² = 3.47 ksi

Design Shear Stress of the Bolt = 156 # / 0.196 in² = 0.79 ksi

F_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksi

F_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksi

f_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$



Applying the equation above to find the allowable tension stress at this shear;

$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 1/2" diameter A325 bolt is sufficient for this application ✓

TAG: UUT-11



— (6) 1/2" Ø SAE GRADE 8 /
ASTM A490 BOLTS

Note:
1) All Dimensions are in Inches
2) See Yaskawa dwg# DD.Z1.1.F1.02
for details.

CERTIFIED FOR:

JOB NAME: Baseline VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-11 STEEL ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

39 OF 76

MEMBER

VMC
The Power of Together

THE VMC GROUP
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 40 of 76
CUSTOMER Yaskawa	BY RJH	DATE 3/31/2015	CHECKED DATE

X-iv-d. Seismic Force Calculation: UUT-11

() LRFD () ASD () AC-156

Ss =	3.00	ap =	2.5	From the tables:				
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	4.80 g's
Occupancy Category	IV	Calculated Seismic Design Category		D		DL	E	
Mfr	Yaskawa	Model	N/A			Load Combination 1	1.2	1
						Load Combination 2	0.9	

Calculate the maximum loading at the most critical anchor location.

Principal Axis Calculation

Input Data						Calculated Loads		
W	horzg's	vertg's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min
950 #	1.500	0.500	1.600	47.58"	19.27"	13.57"	1425 #	1520 #
Restraint Locations		ly1	lx1	Ixy	J1	Oversetting Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert Min Vert
1	1.05"	1.05"	313	87	165	400	-2056 #	149 #
2	1.05"	19.68"	313	87	-165	400	1164 #	312 #
3	36.45"	1.05"	313	87	-165	400	-1164 #	163 #
4	36.45"	19.68"	313	87	165	400	2056 #	326 #
Center of Restraints		ly total	lx total	Ixy total	J total	0 #	950 #	1520
18.8"	10.4"	1253	347	0	1600		0	475
Cx 17.7"	Cy 9.3"	# Vertical Restraints 4	# Horizontal Restraints 4		Theta 27.8 deg	Tanθ 0.484 rad	r max 0.526	20.0"
	Mx	My	Mxly-Myly	Mylx-Mxly	lxly-lxy ²	Max Loads per Location		
Fp Only	60000	31576	7.52E+07	1.10E+07	4.35E+05	Comp (Max Vert)	2578 #	
					Mz	Tens. (Min Vert)	1982 #	
Static Vert	3045	494	3.82E+06	1.71E+05	4627	Shear	414 #	

Design Tension = 1982#

Design Shear = 414#

Equipment is attached to concrete with (4) Hilti Kwik Bolt TZ-CS, 1/2" Dia. with 3.25" min. embedment

Edge distance of 6" on a 6" thick concrete pad of 4000Psi


Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ - CS 1/2 (3 1/4)
Effective embedment depth:	$h_{ef,act} = 3.250$ in., $h_{nom} = 3.625$ in.
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318-11 / Mech.
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.375$ in.
Anchor plate:	$l_x \times l_y \times t = 2.000$ in. $\times 2.000$ in. $\times 0.375$ in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f_c' = 4000$ psi; $h = 6.000$ in.
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))



Geometry [in.] & Loading [lb, in.lb]



Company:
Specifier:
Address:
Phone / Fax:
E-Mail:



Page: 42
Project:
Sub-Project / Pos. No.:
Date: 4/1/2015

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Pullout Strength	1982	3031	66 / -	OK
Shear	Concrete edge failure in direction x+	414	2868	- / 15	OK
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V} [\%]$
Combined tension and shear loads		0.654	0.144	5/3	54

Fastening meets the design criteria!

TAG: UUT-11



(4) 1/2" Ø HILTI KWIK BOLT TZ-CS
MIN. 3.25" EMBEDMENT
6" EDGE DISTANCE
4000 PSI CONCRETE
W/ 6" THICK.

Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.1.F1.02 for details.

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-11 CONCRETE ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

43 OF 76

Member
VISCAM

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS				JOB / DWG NUMBER VMA-49850-1A			REV. NO. 00	SHEET NO. 44 of 76																																													
CUSTOMER Yaskawa				BY RJH	DATE 4/1/2015	CHECKED	DATE																																														
X-v-a. Seismic Force Calculation: UUT-12																																																					
<input type="radio"/> LRFD <input checked="" type="radio"/> ASD <input type="radio"/> AC-156																																																					
<table border="1"> <tr><td>S_s =</td><td>3.00</td><td>a_p =</td><td>2.5</td><td colspan="5">From the tables:</td></tr> <tr><td>z/h =</td><td>1.0</td><td>R_p =</td><td>6</td><td>F_a =</td><td>1.00</td><td></td><td>Min. limit</td><td>Actual</td></tr> <tr><td>Site Class</td><td>D</td><td>I_p =</td><td>1.5</td><td>S_{DS} =</td><td>2.000</td><td>F_p/W_p =</td><td>0.90 g's</td><td>1.50 g's</td></tr> <tr><td>Occupancy Category</td><td>IV</td><td colspan="3">Calculated Seismic Design Category</td><td>D</td><td>DL</td><td>E</td></tr> <tr><td>Mfr</td><td>Yaskawa</td><td>Model</td><td>N/A</td><td colspan="3">Load Combination 1</td><td>1</td><td>0.7</td></tr> <tr><td colspan="9">Calculate the maximum loading at the most critical anchor location.</td></tr> </table>	S _s =	3.00	a _p =	2.5	From the tables:					z/h =	1.0	R _p =	6	F _a =	1.00		Min. limit	Actual	Site Class	D	I _p =	1.5	S _{DS} =	2.000	F _p /W _p =	0.90 g's	1.50 g's	Occupancy Category	IV	Calculated Seismic Design Category			D	DL	E	Mfr	Yaskawa	Model	N/A	Load Combination 1			1	0.7	Calculate the maximum loading at the most critical anchor location.								
	S _s =	3.00	a _p =	2.5	From the tables:																																																
	z/h =	1.0	R _p =	6	F _a =	1.00		Min. limit	Actual																																												
	Site Class	D	I _p =	1.5	S _{DS} =	2.000	F _p /W _p =	0.90 g's	1.50 g's																																												
	Occupancy Category	IV	Calculated Seismic Design Category			D	DL	E																																													
	Mfr	Yaskawa	Model	N/A	Load Combination 1			1	0.7																																												
Calculate the maximum loading at the most critical anchor location.																																																					
Principal Axis Calculation																																																					
Input Data						Calculated Loads																																															
W	horz g's	vert g's	H _{cg}	X _{cg}	Y _{cg}	P _{hx}	P _{z Max}	P _{z Min}																																													
2100 #	1.050	0.320	1.280	42.74"	33.96"	12.57"	2205 #	2688 #	672 #																																												
Restraint Locations		l _{y1}	l _{x1}	l _{xy}	J1	Overspinning Loads (F _p Only)	Rigid Weight Distribution	Seismic Vertical Distribution																																													
X	Y	(X-X _{cr}) ²	(Y-Y _{cr}) ²	(X-X _{cr}) [*] (Y-Y _{cr})	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert	Min Vert																																												
1	1.00"	1.00"	1032	196	450	1228	1480 #	432 #	2033	1618																																											
2	1.00"	15.00"	1032	0	0	1032	-136 #	341 #	300	-27																																											
3	1.00"	29.00"	1032	196	-450	1228	-1752 #	250 #	-1433	-1673																																											
4	65.25"	1.00"	1032	196	-450	1228	1752 #	450 #	2329	1897																																											
5	65.25"	15.00"	1032	0	0	1032	136 #	359 #	596	251																																											
6	65.25"	29.00"	1032	196	450	1228	-1480 #	268 #	-1137	-1394																																											
Center of Restraints 33.1" 15.0"		l _{y total} 6192	l _{x total} 784	l _{xy total} 0	J _{total} 6976	0 #	2100 # 0	2688 0	672 0																																												
C _x 32.1"	C _y 14.0"	# Vertical Restraints 6	# Horizontal Restraints 6	Theta 163.8 deg			Tan<θ> 0.283 rad	-0.291	r max 35.0"																																												
Max Loads per Location																																																					
F _p Only	-90500	26293	-5.60E+08	2.06E+07	4.85E+06	Comp (Max Vert)	2329 #																																														
					M _z	Tens. (Min Vert)	1673 #																																														
Static Vert	-5103	1754	-3.16E+07	1.37E+06	5666	Shear	396 #																																														



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 45 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-v-b. Check Bolting of Equipment to Structural steel

Tag: UUT-12

Bolting using 1/2" diameter SAE Grade 8/ ASTM A490 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.500	0.196 in^2	1673 #	396 #	8.52 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel Structure

Stress Area = 0.196 in²

Design Tension Stress of the Bolt = 1673 # / 0.196 in² = 8.52 ksi

Design Shear Stress of the Bolt = 396 # / 0.196 in² = 2.02 ksi

F_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksi

F_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksi

f_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$




Applying the equation above to find the allowable tension stress at this shear;

$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 1/2" diameter A325 bolt is sufficient for this application ✓

TAG: UUT-12



Note:
1) All Dimensions are in Inches
2) See Yaskawa dwg# DD.Z1.3R.F2.02
for details.

3) See Yaskawa dwg # USP03233 for
mounting foot details

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-12 STEEL ANCHORAGE LAYOUT



SCALE:
NONE

SHEET:
46 OF 76

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

Member

VISCAM

DRAWING NO.: VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 47 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-v-d. Seismic Force Calculation: UUT-12

LRFD ASD AC-156

Ss =	3.00	ap =	2.5	From the tables:				
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	4.80 g's
Occupancy Category	IV	Calculated Seismic Design Category		D		DL	E	
Mfr	Yaskawa	Model	N/A			Load Combination 1	1.2	1
Calculate the maximum loading at the most critical anchor location.								
Load Combination 2 0.9								

Principal Axis Calculation

Input Data						Calculated Loads		
W	horz g's	vert g's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min
2100 #	1.500	0.500	1.600	42.74"	33.96"	12.57"	3150 #	3360 #
Restraint Locations	ly1	lx1	lxy	J1	Oversetting Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution	
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert
1	1.00"	1.00"	1032	196	450	1228	2114 #	432 #
2	1.00"	15.00"	1032	0	0	1032	-195 #	341 #
3	1.00"	29.00"	1032	196	-450	1228	-2504 #	250 #
4	65.25"	1.00"	1032	196	-450	1228	2504 #	450 #
5	65.25"	15.00"	1032	0	0	1032	195 #	359 #
6	65.25"	29.00"	1032	196	450	1228	-2114 #	268 #
Center of Restraints		ly total	lx total	lxy total	J total	0 #	2100 #	3360
33.1"	15.0"	6192	784	0	6976		0	0
Cx	Cy	# Vertical Restraints	# Horizontal Restraints		Theta	Tanθ	r max	
32.1"	14.0"	6	6		163.8 deg	0.283 rad	-0.291	35.0"
	Mx	My	Mxly-Mylxy	Mylx-Mxlxy	lxly-lxy ²	Max Loads per Location		
Fp Only	-129285	37561	-8.01E+08	2.94E+07	4.85E+06	Comp (Max Vert)	3224 #	
					Mz	Tens. (Min Vert)	2379 #	
Static Vert	-5103	1754	-3.16E+07	1.37E+06	8094	Shear	566 #	

Design Tension =

2379#

Design Shear =

566#

Equipment is attached to concrete with (4) Hilti Kwik Bolt TZ-CS, 1/2" Dia. with 3.25" min. embedment
Edge distance of 6" on a 6" thick concrete pad of 4000Psi


Specifier's comments:

1 Input data

Anchor type and diameter:	Kwik Bolt TZ - CS 1/2 (3 1/4)
Effective embedment depth:	$h_{ef,act} = 3.250$ in., $h_{nom} = 3.625$ in.
Material:	Carbon Steel
Evaluation Service Report:	ESR-1917
Issued Valid:	5/1/2013 5/1/2015
Proof:	design method ACI 318-11 / Mech.
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.375$ in.
Anchor plate:	$l_x \times l_y \times t = 2.000$ in. $\times 2.000$ in. $\times 0.375$ in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f_c' = 4000$ psi; $h = 6.000$ in.
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))



Geometry [in.] & Loading [lb, in.lb]



Company:
Specifier:
Address:
Phone / Fax:
E-Mail:


Page: 49
Project:
Sub-Project / Pos. No.:
Date: 4/1/2015

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Pullout Strength	2379	3031	79 / -	OK
Shear	Concrete edge failure in direction x+	566	2868	- / 20	OK
Loading	Combined tension and shear loads	β_N 0.785	β_V 0.197	ζ 5/3	Utilization $\beta_{N,V} [\%]$ 74

Fastening meets the design criteria!

TAG: UUT-12



(6) 1/2" Ø HILL-TI KWIK BOLT TZ-CS
MIN 3.25" EMBEDMENT
6" EDGE DISTANCE
4000 PSI CONCRETE
W/ 6" THICK.

Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.3R.F2.02 for details.
- 3) See Yaskawa dwg # USP03233 for mounting foot details

CERTIFIED FOR:

JOB NAME: Phase II VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-12 CONCRETE ANCHORAGE LAYOUT



SCALE:
NONE
SHEET:
50 OF 76

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION

Member
VISCAM



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 51 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-vi-a. Seismic Force Calculation: UUT-13

LRFD

ASD

AC-156

Ss =	3.00	ap =	2.5	From the tables:						
z/h =	1.0	Rp =	6	Fa = 1.00						
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	1.50 g's		
Occupancy Category	IV	Calculated Seismic Design Category			D	DL E				
Mfr	Yaskawa	Model	N/A	Load Combination 1			1	0.7		
Calculate the maximum loading at the most critical anchor location.										
Principal Axis Calculation										
Input Data						Calculated Loads				
W	horz g's	vert g's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min		
2200 #	1.050	0.320	1.280	39.40"	36.53"	2310 #	2816 #	704 #		
Restraint Locations		ly1	Ix1	Ixy	J1	Oversetting Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution		
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert	Min Vert	
1	1.05"	1.05"	1006	87	295	1093	-2546 #	375 #	-2066	-2426
2	1.05"	19.68"	1006	87	-295	1093	2141 #	595 #	2903	2332
3	64.48"	1.05"	1006	87	-295	1093	-2141 #	505 #	-1495	-1980
4	64.48"	19.68"	1006	87	295	1093	2546 #	725 #	3474	2778
Center of Restraints		ly total 32.8"	Ix total 4023	Ixy total 347	J total 0	0 #	2200 # 0	2816 0	704 0	
Cx 31.7"	Cy 9.3"	# Vertical Restraints 4	# Horizontal Restraints 4	Theta 16.4 deg	Tanθ 0.286 rad	0.294	33.1"			
Max Loads per Location										
Fp Only	Mx 87325	My 25648	Mxly-Mylxy 3.51E+08	Mylx-Mxlxy 8.90E+06	Ixly-Ixy ² 1.40E+06	Comp (Max Vert)	3474 #			
					Mz	Tens. (Min Vert)	2426 #			
Static Vert	4103	8283	1.65E+07	2.87E+06	9706	Shear	651 #			



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 52 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-vi-b. Check Bolting of Equipment to Structural steel

Tag: UUT-13

Bolting using 1/2" diameter SAE Grade 8/ ASTM A490 bolt at each bolt location

Fastener		Loading		Fastener Stress	
Type	Diameter	Area	Tension	Shear	Tension
A325	0.500	0.196 in^2	2426 #	651 #	12.36 ksi

Nominal Stress			Allowable Stress		Pass/Fail	
F _{nt}	F _{nv}	F' _{nt}	F _{t,allow}	F _{v,allow}	Tension	Shear
90 ksi	48 ksi	90 ksi	45 ksi	24 ksi	PASS	PASS

Check Bolting to Steel Structure

Stress Area = 0.196 in^2

Design Tension Stress of the Bolt = 2426 # / 0.196 in^2 = 12.36 ksi

Design Shear Stress of the Bolt = 651 # / 0.196 in^2 = 3.32 ksi

F_{nt} = Nominal Tensile Stress from Table J3.2 = 90 ksi

F_{nv} = Nominal Shear Stress from Table J3.2 = 48 ksi

f_v = Design Shear Stress

Ω = 2.00 (ASD)

From AISC Manual of Steel Construction 13th Edition Section J3.6:

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$


Applying the equation above to find the allowable tension stress at this shear;

$$\frac{F'_{nt}}{\Omega} = F_{t,allowable} = 45 \text{ ksi}$$

$$\frac{F_{nv}}{\Omega} = F_{v,allowable} = 24 \text{ ksi}$$

Therefore, the 1/2" diameter A325 bolt is sufficient for this application ✓

TAG: UUT-11



(4) 1/2" Ø SAE GRADE 8 /
ASTM A490 BOLTS

Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.1.F2.02 for details.

CERTIFIED FOR:

JOB NAME: Baseline VFDs Seismic Anchorage

CUSTOMER: Yaskawa

CUSTOMER P.O.: 4200211053

SALES ORDER: 267486

UUT-11 STEEL ANCHORAGE LAYOUT



SCALE:

NONE

SHEET:

53 OF 76

VISCAM
Member

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 54 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED ASD

X-vi-a. Seismic Force Calculation: UUT-13

 LRFD ASD AC-156

Ss =	3.00	ap =	2.5	From the tables:				
z/h =	1.0	Rp =	6	Fa =	1.00		Min. limit	Actual
Site Class	D	Ip =	1.5	S _{DS} =	2.000	Fp/Wp =	0.90 g's	4.80 g's
Occupancy Category	IV	Calculated Seismic Design Category		D		DL	E	
Mfr	Yaskawa	Model	N/A			Load Combination 1	1.2	1
Calculate the maximum loading at the most critical anchor location.								

Principal Axis Calculation

Input Data						Calculated Loads		
W	horzg's	vertg's	Hcg	Xcg	Ycg	Phx	Pz Max	Pz Min
2200 #	1.500	0.500	1.600	39.40"	36.53"	12.23"	3300 #	3520 #
Restraint Locations		ly1	lx1	Ixy	J1	Oversetting Loads (Fp Only)	Rigid Weight Distribution	Seismic Vertical Distribution
X	Y	(X-Xcr) ²	(Y-Ycr) ²	(X-Xcr)* (Y-Ycr)	r ²	P _{ot} (Tens = -)	Static 1.0 g Vert	Max Vert Min Vert
1	1.05"	1.05"	1006	87	295	1093	-3637 #	375 #
2	1.05"	19.68"	1006	87	-295	1093	3059 #	595 #
3	64.48"	1.05"	1006	87	-295	1093	-3059 #	505 #
4	64.48"	19.68"	1006	87	295	1093	3637 #	725 #
Center of Restraints		ly total	lx total	Ixy total	J total	0 #	2200 #	3520
32.8"	10.4"	4023	347	0	4370		0	0
Cx 31.7"	Cy 9.3"	# Vertical Restraints 4	# Horizontal Restraints 4		Theta 16.4 deg	Tanθ 0.286 rad	r max 0.294	33.1"
	Mx	My	Mxly-Myly	Mylx-Mxlly	lxly-lxy ²	Max Loads per Location		
Fp Only	124750	36640	5.02E+08	1.27E+07	1.40E+06	Comp (Max Vert)	4798 #	
					Mz	Tens. (Min Vert)	3450 #	
Static Vert	4103	8283	1.65E+07	2.87E+06	13865	Shear	930 #	


Design Tension = 3450#

Design Shear = 930#

Equipment is attached to concrete with (4) HIT-HY 200 + HIS-N B7, 1/2" Dia. with 5" min. embedment
 Edge distance of 8" on a 8" thick concrete pad of 4000Psi

Specifier's comments:**1 Input data**

Anchor type and diameter:	HIT-HY 200 + HIS-N B7 1/2
Effective embedment depth:	$h_{ef,act} = 5.000$ in., $h_{nom} = 5.000$ in.
Material:	ASTM A 193 Grade B7
Evaluation Service Report:	ESR-3187
Issued / Valid:	5/1/2014 3/1/2016
Proof:	design method ACI 318-11 / Chem
Stand-off installation:	$e_b = 0.000$ in. (no stand-off); $t = 0.375$ in.
Anchor plate:	$l_x \times l_y \times t = 2.000$ in. $\times 2.000$ in. $\times 0.375$ in.; (Recommended plate thickness: not calculated)
Profile:	no profile
Base material:	cracked concrete, 4000, $f'_c = 4000$ psi; $h = 8.000$ in., Temp. short/long: 32/32 °F
Installation:	hammer drilled hole, installation condition: dry
Reinforcement:	tension: condition B, shear: condition B; no supplemental splitting reinforcement present edge reinforcement: none or < No. 4 bar
Seismic loads (cat. C, D, E, or F)	Tension load: yes (D.3.3.4.3 (d)) Shear load: yes (D.3.3.5.3 (c))

**Geometry [in.] & Loading [lb, in.lb]**

Company:
Specifier:
Address:
Phone / Fax:
E-Mail:


Page: 56
Project:
Sub-Project / Pos. No.:
Date: 4/1/2015

2 Proof I Utilization (Governing Cases)

Loading	Proof	Design values [lb]		Utilization	
		Load	Capacity	$\beta_N / \beta_V [\%]$	Status
Tension	Bond Strength	3450	3793	91 / -	OK
Shear	Steel Strength	930	4471	- / 21	OK
Loading		β_N	β_V	ζ	Utilization $\beta_{N,V} [\%]$
Combined tension and shear loads		0.909	0.208	5/3	93

Fastening meets the design criteria!

TAG: UUT-11




(4) 1/2" Ø HIT-HY 200 + HIS N B7
MIN. 5" EMBEDMENT
8" EDGE DISTANCE
4000 PSI CONCRETE
W/ 8" THICK.

Note:

- 1) All Dimensions are in Inches
- 2) See Yaskawa dwg# DD.Z1.1.F2.02 for details.

CERTIFIED FOR:

JOB NAME: Base II VFDs Seismic Anchorage
CUSTOMER: Yaskawa
CUSTOMER P.O.: 4200211053
SALES ORDER: 267486



SCALE:
NONE

SHEET:
57 OF 76

THE VMC GROUP
The Power of Together
Bloomingdale, NJ 07403
Houston, TX 77041

DRAWING NO.: VMA-49850 01A

REVISION

VISCAM



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 58 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

Equipment Tag			
UUT-14 on steel structure			
X-vii-a. Seismic Restraint Load Calculation		Load Combinations are as per ASD	
Mfr	Yaskawa	Model	N/A
Input Values			
Coefficient	Value	Units	Description
X	10.55	in	Equipment Depth
Y	8.7	in	Distance Between Attachment Points Along Unit Width
Z	20.76	in	Distance Between Attachment Points Along Unit Height
m	70	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	5.275	in	Center of Gravity Along Depth Direction
Y _{cg}	4.35	in	Center of Gravity Along Width Direction
Z _{cg}	10.38	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	29	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$


$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T _{max}	40 lbs
------------------	--------


V _{max}	28 lbs
------------------	--------



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 59 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-vii-b. Check screw of Equipment to Structural steel
Tag: UUT-14 using 1/4" diameter screws

Check 1/4" ϕ screw to Steel Structure

Stress Area = 0.0491 in²

Design Tension of the Bolt = 40 lbs.

Design Shear of the Bolt = 28 lbs.

From ICC-ES Report, ESR-2196, Table 2 (page 6 of 10) and Table 4A (page 8 of 10),
Attachment to minimum of gauge 20 steel where the screw head is not in contact,

Allowable tension load is **115 lbs** (Table 2).

Allowable Shear load is **215 lbs** (Table 4A).

Allowable Pullout load 115 lbs > Design Tension load 40 lbs.

Allowable Shear load 215 lbs > Design Shear load 28 lbs.

Therefore, the 1/4" ϕ screw is sufficient for this application ✓



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 60 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

Equipment Tag			
UUT-1 Microdrive on steel structure			
X-viii-a. Seismic Restraint Load Calculation			Load Combinations are as per ASD
Mfr Yaskawa			Model N/A
Input Values			
Coefficient	Value	Units	Description
X	5.6	in	Equipment Depth
Y	4.05	in	Distance Between Attachment Points Along Unit Width
Z	4.65	in	Distance Between Attachment Points Along Unit Height
m	5.3	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	2.8	in	Center of Gravity Along Depth Direction
Y _{cg}	2.025	in	Center of Gravity Along Width Direction
Z _{cg}	2.325	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	27	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$

$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T_{max}


4 lbs

V_{max}


2 lbs



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 61 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-viii-b. Check screw of Equipment to Structural steel
Tag: UUTs-1& 4 (Micro drives) using #8 screws

Check 0.164" φ screw to Steel Structure

Stress Area = 0.0211 in²

Design Tension of the Bolt = 4 lbs.

Design Shear of the Bolt = 2 lbs.

From ICC-ES Report, ESR-2196, Table 2 (page 6 of 10) and Table 4A (page 8 of 10),
Attachment to minimum of gauge 20 steel where the screw head is not in contact,

Allowable tension load is **75 lbs** (Table 2).

Allowable Shear load is **174 lbs** (Table 4A).

Allowable Pullout load 75 lbs > Design Tension load 4 lbs.

Allowable Shear load 174 lbs > Design Shear load 2 lbs.

Therefore, the #8 screw is sufficient for this application



Please refer to Yaskawa drawing DD.J1K.FR11.IP20 for mounting



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 62 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

Equipment Tag			
UUT-2 Microdrive on steel structure			
X-ix-a. Seismic Restraint Load Calculation			Load Combinations are as per ASD
Mfr Yaskawa			Model N/A
Input Values			
Coefficient	Value	Units	Description
X	7	in	Equipment Depth
Y	6.22	in	Distance Between Attachment Points Along Unit Width
Z	4.65	in	Distance Between Attachment Points Along Unit Height
m	6.6	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	3.5	in	Center of Gravity Along Depth Direction
Y _{cg}	3.11	in	Center of Gravity Along Width Direction
Z _{cg}	2.325	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	30	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$

$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T_{max}


6 lbs

V_{max}


3 lbs



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 63 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-ix-b. Check screw of Equipment to Structural steel
Tag: UUT-2(Micro drive) using #8 screws

Check 0.164" φ screw to Steel Structure

Stress Area = 0.0211 in²

Design Tension of the Bolt = 6 lbs.
Design Shear of the Bolt = 3 lbs.

From ICC-ES Report, ESR-2196, Table 2 (page 6 of 10) and Table 4A (page 8 of 10),
Attachment to minimum of gauge 20 steel where the screw head is not in contact,

Allowable tension load is **75 lbs** (Table 2).

Allowable Shear load is **174 lbs** (Table 4A).

Allowable Pullout load 75 lbs > Design Tension load 6 lbs.

Allowable Shear load 174 lbs > Design Shear load 3 lbs.

Therefore, the #8 screw is sufficient for this application





THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 64 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

Equipment Tag			
UUT-3 Microdrive on steel structure			
X-x-a. Seismic Restraint Load Calculation			Load Combinations are as per ASD
Mfr Yaskawa			Model N/A
Input Values			
Coefficient	Value	Units	Description
X	7.36	in	Equipment Depth
Y	7.56	in	Distance Between Attachment Points Along Unit Width
Z	13.23	in	Distance Between Attachment Points Along Unit Height
m	20.2	lbs	Equipment Mass
g _h	1.05	g	F _{p,h} / W _p = Horizontal Seismic Acceleration
g _v	1.28	g	(F _{p,v} / W _p + W _p) = Vertical Seismic Acceleration
X _{cg}	3.68	in	Center of Gravity Along Depth Direction
Y _{cg}	3.78	in	Center of Gravity Along Width Direction
Z _{cg}	6.615	in	Center of Gravity Along Height Direction
Critical Angle			
Coefficient	Value	Units	Description
φ	33	degrees	Worst Case Angle to Apply Seismic Acceleration

$$mg_{h,x} = (F_{p,h}/W_p)\sin(\phi)$$


$$mg_{h,y} = (F_{p,h}/W_p)\cos(\phi)$$

$$T_{max} = \frac{mg_v X_{cg}}{2Z} + \frac{mg_{h,x}(Z_{cg} - Z/2)}{2Z} + \frac{mg_{h,x}}{4} + \frac{mg_{h,y} X_{cg}}{2Y} + \frac{mg_{h,x}(|Y_{cg} - Y/2|)}{2Y}$$


$$V_{max} = \sqrt{\left(\frac{mg_v}{4}\right)^2 + \left(\frac{mg_{h,y}}{4}\right)^2}$$

T _{max}	11 lbs
------------------	--------


V _{max}	8 lbs
------------------	-------



Isometric View



Plan View



Side Elevation View



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls

PROJECT Yaskawa VFDs Phase II OSP & IBCS	JOB / DWG NUMBER VMA-49850-1A	REV. NO. 00	SHEET NO. 65 of 76
CUSTOMER Yaskawa	BY RJH	DATE 4/1/2015	CHECKED DATE

X-x-b. Check screw of Equipment to Structural steel
Tag: UUT-3 (Micro drive) using 1/4 diameter screws

Check 1/4" ϕ screw to Steel Structure

Stress Area = 0.0491 in²

Design Tension of the Bolt = 11 lbs.

Design Shear of the Bolt = 8 lbs.

From ICC-ES Report, ESR-2196, Table 2 (page 6 of 10) and Table 4A (page 8 of 10),
Attachment to minimum of gauge 20 steel where the screw head is not in contact,


Allowable tension load is **115 lbs** (Table 2).

Allowable Shear load is **215 lbs** (Table 4A).

Allowable Pullout load 115 lbs > Design Tension load 11 lbs.

Allowable Shear load 215 lbs > Design Shear load 8 lbs.

Therefore, the 1/4" ϕ screw is sufficient for this application ✓



NOTES:

- FOR REFERENCE ONLY UNLESS PROPERLY ENDORSED.
FOR ADDITIONAL DETAILS AND
SPECIFICATIONS, CONSULT FACTORY.
- DIMENSIONS ARE IN INCHES [MILLIMETERS].
- HATCHED AREA INDICATES PERMISSIBLE
CONDUIT ENTRANCE AREA.
- FANS, FILTERS, LEG STANDS OR CLOSING PLATES ARE
SUPPLIED WHEN OPTION MIX NECESSITATES.
- USE APPROPRIATE TYPE RATED HUBS OR
FITTINGS TO MAINTAIN ENCLOSURE RATING.


 **YASKAWA**™

THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

DRAWN: JDE		DATE: 04/25/13	TITLE: DIMENSION DRAWING, Z1000 TYPE 3R, W1		
CHECKED: RKM		DATE: 04/25/13	MATERIAL# ----		
TECH:	DATE		SIZE A	REVISION 02	PAGE 1 OF 2
APPROVED: BJJ	DATE 05/02/13				
ORIGINAL DESIGN: JDE	DATE 04/19/13				
DRAWING #: DD.Z1.3R.W1.01					

REVISIONS

REV.	DESCRIPTION	DRAWN BY	ECO	DATE
02	ADDED NEW 12" AND 30" LEG STANDS	JDE	4526	9/11/13
01	ADDED NEW 12" AND 30" LEG STANDS	JDE	4462	8/14/13
00	INITIAL RELEASE	JDE	-	4/25/13




NOTES:


- A. FOR REFERENCE ONLY UNLESS PROPERLY ENDORSED.
FOR ADDITIONAL DETAILS AND
SPECIFICATIONS, CONSULT FACTORY.
- B. DIMENSIONS ARE IN INCHES [MILLIMETERS].
- C. HATCHED AREA INDICATES PERMISSIBLE
CONDUIT ENTRANCE AREA.
- D. FANS, FILTERS, LEG STANDS OR CLOSING PLATES ARE
SUPPLIED WHEN OPTION MIX NECESSITATES.
- E. USE APPROPRIATE TYPE RATED HUBS OR
FITTINGS TO MAINTAIN ENCLOSURE RATING.



THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

REVISIONS				DRAWN BY	ECO	DATE	TITLE: DIMENSION DRAWING, Z1000 TYPE 3R, W4		
REV.	DESCRIPTION	DRAWN BY	ECO	DATE			APPROVED:	DATE	MATERIAL#
02	ADDED NEW 12" AND 30" LEG STANDS	JDE	4526	9/11/13	RKM	04/25/13	BJJ	05/02/13	---
01	ADDED NEW 12" AND 30" LEG STANDS	JDE	4462	8/19/13			ORIGINAL DESIGN:	DATE	A 02
00	INITIAL RELEASE	JDE	-	4/25/13			JDE	04/19/13	1 OF 2







THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

REVISIONS					DRAWN BY	DATE	TITLE: DIMENSION DRAWING Z1000,F1,TYPE 3R		
REV.	DESCRIPTION	ECO #	DRAWN BY	DATE	JDE	04/26/13	SIZE	REVISION	PAGE
00	INITIAL RELEASE	-	JDE	4/26/13	RKM	04/26/13	A	00	1 OF 1
					APPROVED:	DATE			
					BJJ	05/03/13			
					ORIGINAL DESIGN:	DATE			
					JDE	04/19/13	DRAWING #:	DD.Z1.3R.F1.02	


FRONT MOUNTING HOLE
TO FRONT OF
DOOR HANDLE

5.00
[127]
MINIMUM
CLEARANCE



TOP VIEW


RECOMMENDED
CONDUIT ENTRANCE AREA



56.47
[1434]
DOOR OPEN 90°

21.75
552

1.60
41



BOTTOM VIEW


NOTES:

- A. FOR REFERENCE ONLY UNLESS PROPERLY ENDORSED.
FOR ADDITIONAL DETAILS AND SPECIFICATIONS,
CONSULT WITH FACTORY.
- B. DIMENSIONS ARE IN INCHES [MILLIMETERS]
- C. ALL DIMENSIONS ARE PER LARGEST AVAILABLE OPTIONS.
- D. CLOSING PLATE IS ONLY USED ON NATURALLY ASPIRATED
ENCLOSURES.
- E. USE APPROPRIATE TYPE RATED HUBS OR FITTINGS TO
MAINTAIN ENCLOSURE RATING.
- F. TOTAL DEPTH VARIES PER DRIVE HORSEPOWER RATING
(NOT TO EXCEED 9.24 [235])




THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

DRAWN: DDG	DATE: 11/1/11	TITLE: DIMENSION DRAWING Z1000, F1, TYPE 1
CHECKED: KF	DATE: 11/2/11	MATERIAL#
TECH:	DATE	SIZE A
APPROVED: JZ	DATE 11/2/11	REVISION 02
ORIGINAL DESIGN: DDG	DATE 11/1/11	PAGE 1 OF 2
		DRAWING #: DD.Z1.1.F1.02




THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

DRAWN:	DATE	TITLE:
JDE	04/26/13	DIMENSION DRAWING
CHECKED:	DATE	Z1000 F2, TYPE 3R
RKM	04/26/13	MATERIAL# ---
TECH:	DATE	SIZE A REVISION 00 PAGE 1 OF 1
APPROVED:	DATE	DRAWING #:
BJJ	05/03/13	DD.Z1.3R.F2.01
ORIGINAL DESIGN:	DATE	04/19/13







THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA AMERICA INC.

DRAWN: M. DEWEY	DATE 06/05/13	TITLE: OUTLINE DRAWING	
CHECKED: B. JOHNSON	DATE 06/06/13	Z1000 F2,TYPE 1	
TECH:	DATE	MATERIAL#	
APPROVED: K. FLIERL	DATE 06/06/13	SIZE A	REVISION 00
ORIGINAL DESIGN: D. PACKER	DATE 01/23/13	PAGE 1 OF 1	DRAWING #: DD.Z1.1.F2.01



1 2 3 4 5 6 7 8



MODEL # CIMR-JU	VOLTAGE THREE PHASE (VAC)	OUTPUT CURRENT (A)		WEIGHT LBS (Kg)	HEAT LOSS (W)					
		ND	HD		ND (Fc=2kHz)		HD (Fc=8kHz)			
		INT	EXT		INT	EXT	INT	EXT	TOT	
2A0020BXX	208/240	19.6	17.5	5.3 (2.4)	46.3	98.7	145.0	43.3	110.5	153.8
4A0011BXX	380/480	11.1	9.2	5.3 (2.4)	46.0	81.7	127.7	41.5	107.2	148.7

NOTE:
XX DENOTES AA-ZZ

INT=INTERNAL COMPONENTS
EXT=EXTERNAL HEATSINK
TOT=TOTAL

FOR ADDITIONAL DETAILS AND SPECIFICATIONS, CONSULT MANUAL

TOLERANCES / REFERENCES:



THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA ELECTRIC AMERICA INC.

DRAWN:

J. MATTAS

CHECKED:

J. PIOTROWSKI

TECH:

J. CAIRO

APPROVED:

T. SASADA

ORIGINAL DESIGN:

DATE:

8-1-08

DATE:

4-16-09

DATE:

5-11-09

DATE:

5-14-09

DATE:

-

TITLE:

J1000 DIMENSION DRAWING
FRAME SIZE 11
OPEN ENCLOSURE (IP20 RATING)
2A0020B & 4A0011B

SIZE

A

REVISION

R00

PAGE

1 of 3

DRAWING #:

DD.J1K.FR11.IP20


UNITS:

IN [mm]




SCALE:

1: 4

1 2 3 4 5 6 7 8



(2) COOLING FANS



MODEL # CIMR-VU	VOLTAGE SINGLE PHASE (VAC)	OUTPUT CURRENT (A)		WEIGHT LBS (Kg)	HEAT LOSS (W)					
					ND (Fc=2kHz)			HD (Fc=8kHz)		
		INT	EXT	TOT	INT	EXT	TOT	INT	EXT	TOT
BA0018BXX	208/240	-	17.5	6.6 (3.0)	-	-	-	51.4	110.5	161.9

NOTE:
XX DENOTES AA-ZZ

INT=INTERNAL COMPONENTS
EXT=EXTERNAL HEATSINK
TOT=TOTAL

FOR ADDITIONAL DETAILS AND SPECIFICATIONS, CONSULT MANUAL

TOLERANCES / REFERENCES:



THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA ELECTRIC AMERICA INC.

DRAWN:

J. MATTAS

1-27-09

CHECKED:

J. PIOTROWSKI

8-21-09

TECH:

J. CAIRO

8-24-09

APPROVED:

T. SASADA

8-28-09


ORIGINAL DESIGN:

-




DATE

-

1 2 3 4 5 6 7 8



(2) COOLING FANS



MODEL #	VOLTAGE THREE PHASE (VAC)	OUTPUT CURRENT (A)		WEIGHT LBS (Kg)	HEAT LOSS (W)							
		ND	HD		ND (Fc=2kHz)	HD (Fc=8kHz)	INT	EXT	TOT	INT	EXT	TOT
2A0069AXX	208/240	69.0	60.0	19.1 (8.7)	184.5	461.7	646.2	151.4	437.7	589.1		

NOTE:
XX DENOTES AA-ZZ

INT=INTERNAL COMPONENTS
EXT=EXTERNAL HEATSINK
TOT=TOTAL

FOR ADDITIONAL DETAILS AND SPECIFICATIONS, CONSULT MANUAL

TOLERANCES / REFERENCES:



THIS DOCUMENT AND INFORMATION CONTAINED
IN IT ARE CONFIDENTIAL, AND CANNOT BE
COPIED OR DISCLOSED IN WHOLE OR IN PART
WITHOUT THE EXPRESS WRITTEN CONSENT
OF YASKAWA ELECTRIC AMERICA INC.

DRAWN:

J. MATTAS

DATE

1-29-09

TITLE:

V1000 DIMENSION DRAWING
FRAME SIZE 17
OPEN ENCLOSURE (IP00 RATING)
2A0069A

SIZE

A

REVISION

R00

PAGE

1 of 3

DRAWING #:

DD.V1K.FR17.IP00

UNITS:

IN [mm]

SCALE:

1: 5

S U B M I T T E D B Y



THE VMC GROUP

Aeroflex International Isolators | Amber/Booth | Korfund Dynamics | Vibration Mountings & Controls