

PRODUCT DESCRIPTION

RATING (SELECT ONLY ONE)

RATED INPUT	DRIVE MODEL NO.	120% CONTINUOUS OUTPUT CURRENT (A)	NOMINAL HP	BASE NO.
208V	A130	130	40	DB0
	A160	160	50	DC0
	A192	192	60	DD0
	A248	248	75	DE0
	A312	300	100	DF0
230V	A130	130	50	AD0
	A160	160	60	AD0
	A192	192	75	AE0
	A248	248	100	AF0
	A312	312	125	AG0
460V	B128	128	100	BF0
	B180	156	125	BG0
	B180	180	150	BH0
	B240	240	200	BJ0
	B302	300	250	BK0
	B380	380	300	BL0
	B506	414	350	BM0
	B506	506	400	BN0
B875	515	450	BP0	
B875	675	500	BR0	

OPTION TABLE 1

ENCLOSURE TYPE	OPTION DESIG.
NEMA 1 VENTED	V
BLOWERED	B

OPTION TABLE 2

OPTION DESIGNATOR	DESCRIPTION
Y1	2CN OPTION - CM043 METASYS N2 COMMUNICATIONS
Y2	2CN OPTION - CM045 FLN COMMUNICATIONS
Y3	2CN OPTION - CM047 ECHELON COMMUNICATIONS
Y4	2CN OPTION - CM086 RS-232 TO RS-485 INTERFACE
Y5	2CN OPTION - DS006 ANALOG MONITOR - V/I
SEE TABLE 3 FOR OPTION DESIG.	"RUNNING ON BYPASS" AND "RUNNING ON DRIVE" PILOT LIGHTS
T	RFI NOISE SUPPRESSION NETWORK
S	ENGRAVED DRIVE CABINET NAMEPLATE
R	MANUAL SPEED POT
F	AUTO TRANSFER TO BYPASS UPON DRIVE FAULT
S	SMOKE PURGE
R	INPUT REACTOR
P	PRESSURE TRANSDUCER (3-15 PSI)
F	INPUT FUSING
E	INPUT RFI FILTER

NOTES:

- * COMPONENTS NOT SUPPLIED BY YASKAWA.
 - CUSTOMER WIRING. - FOR 0 TO 100 AMPS, USE 60°-75° COPPER WIRE. ABOVE 100 AMPS, USE 75° COPPER WIRE.
 - CUSTOMER CONNECTION POINT ON PANEL MOUNTED TERMINAL BLOCK TB1. TORQUE WIRE CONNECTIONS TO 16-20 LB. IN.
 - FACTORY CONNECTION POINT ON DRIVE A1.
- REFER TO THE PRODUCT DESCRIPTION AND ASSOCIATED OPTION TABLES TO DETERMINE WHICH OPTIONS ARE PRESENT.
- CONNECTED TO CABINET. CUSTOMER TO CONNECT CABINET GROUND LEG TO EARTH GROUND.
 - MOTOR OVERLOAD RELAY, S12, IS FACTORY SET FOR MANUAL RESET. CUSTOMER TO ADJUST S12 TRIP SETTING FOR THE AC MOTOR'S FULL LOAD AMPS.
 - TERMINALS SUPPLIED FOR INSERTION OF NORMALLY CLOSED CUSTOMER SAFETY CONTACTS I.E. FIRESTAY, FREEZE/STAY, WINDING OR BEARING TEMPERATURE ACTIVATED SWITCHES. IF APPLICABLE, REMOVE THE FACTORY INSTALLED JUMPER J1.
 - A. TERMINALS SUPPLIED FOR INSERTION OF CUSTOMER SUPPLIED DAMPER ELECTRIC PNEUMATIC VALVE (SOLENOID), WITH A MAXIMUM POWER RATING OF 100VA SEALED AND 170MA INRUSH, USED TO CONTROL THE OPENING AND CLOSING OF A SYSTEM DAMPER. IF APPLICABLE, CHANGE DRIVE PARAMETER n004 TO 1.
B. TERMINALS SUPPLIED FOR INSERTION OF CUSTOMER SUPPLIED, NORMALLY OPEN DAMPER END SWITCH (OPEN-DAMPER CLOSED, CLOSED-DAMPER FULLY OPEN). IF APPLICABLE, REMOVE THE FACTORY INSTALLED JUMPER J2.
 - INSULATED TWISTED SHIELDED WIRE IS REQUIRED. 2 CONDUCTOR #18GA. (BELDON #8780, OR EQUIVALENT). SHIELD TO CONNECT TO PROPER TERMINAL AS SHOWN. CONNECT THE SHIELD ONLY AT THIS END. STRIP AND ISOLATE THE OTHER END. DO NOT RUN THESE WIRES IN THE SAME CONDUIT AS THE AC POWER AND AC CONTROL WIRES.
 - DRIVE PARAMETER n070 IS PROVIDED TO PREVENT THE DRIVE FROM STARTING INTO A SPINNING MOTOR FOLLOWING A TRANSITION FROM THE BYPASS MODE TO THE DRIVE MODE OF OPERATION. CUSTOMER TO FIELD ADJUST n070 FOR THE DECELERATION TO STOP TIME (IN SECONDS) OF THE AC MOTOR FROM MAXIMUM SPEED, WHEN SWITCHING FROM THE BYPASS TO THE DRIVE MODE OF OPERATION.
 - WHEN PRESSURE TRANSDUCER (OPTION P) IS PRESENT (SEE OPTION TABLE 2), CONNECT THE PNEUMATIC SIGNAL AS SHOWN ON PAGE 1. SET PARAMETER n044 TO "0", AND CUT JUMPER J1 ON THE DRIVE CONTROL BOARD.
 - IF A "2 WIRE" OR "3 WIRE" INITIALIZATION IS PERFORMED ON THE DRIVE, THEN THE DRIVE PARAMETERS NEED TO BE RE-ENTERED, AS SHOWN IN THE SPECIAL PARAMETER SETTINGS TABLES 4 AND 5.
 - IF RUN/STOP IS TO BE PERFORMED VIA THE DRIVE KEYPAD, THEN THE CUSTOMER SAFETY INTERLOCK, THE DAMPER CONTROL AND THE DAMPER END SWITCH WILL NO LONGER FUNCTION. CONTACT THE FACTORY IF THESE FUNCTIONS ARE REQUIRED.
 - SERIAL COMMUNICATIONS RUN/STOP CONTROL: THE CUSTOMER MUST ADD A JUMPER J4 BETWEEN POINTS 3 AND 4 ON THE PANEL MOUNTED TERMINAL BLOCK TB1, AND THE HAND/STOP/AUTO SWITCH, S2 MUST BE IN THE "AUTO" POSITION. IF SERIAL COMMUNICATIONS IS TO BE USED TO CONTROL THE RUN/STOP OF THE DRIVE.

DRIVE OPERATION MODE SELECTION TABLE 5

n002 SETTINGS	RUN/STOP COMMAND	FREQUENCY REFERENCE	SEE NOTE
0	KEYPAD	KEYPAD	9
1	EXT. TERMINALS	KEYPAD	9
2	KEYPAD	EXT. TERMINALS	9
3	EXT. TERMINALS	EXT. TERMINALS	9
4	KEYPAD	SERIAL COMM.	9
5	EXT. TERMINALS	SERIAL COMM.	10
6	SERIAL COMM.	SERIAL COMM.	10
7	SERIAL COMM.	KEYPAD	10
8	SERIAL COMM.	EXT. TERMINALS	10

OPTION COMBINATION TABLE 3

OPTION	OPTION DESIGNATION															
	1	2	3	4	5	6	7	G	H	J	K	L	U	W		
PILOT LIGHTS	0	0	0	0	0	0	1	1	1	1	1	1	1	1		
RFI NOISE SUPPRESSION NETWORK	0	0	0	1	1	1	1	0	0	0	0	1	1	1		
ENGRAVED DRIVE CABINET NAMEPLATE	0	1	1	0	0	1	1	0	0	1	1	0	0	1		
MANUAL SPEED POT	1	0	1	0	1	0	1	0	1	0	1	0	1	0		

SPECIAL PARAMETER SETTINGS TABLE 4 (SEE NOTE 8)

PARAMETER	DATA	UNIT	DESCRIPTION/REMARKS
n001	3	N/A	READ/WRITE TO ALL PARAMETERS
n002	SEE TABLE 5	N/A	DRIVE OPERATION MODE SELECTION
n003	460(230)	V	STANDARD MAX VOLTAGE SETTING
	208	V	MAX VOLTAGE SETTING FOR BASE NO. "D_"
n006	1	N/A	REVERSE RUN DISABLED
n007	0	N/A	LOCAL/REMOTE KEY DISABLED
n018	60.0	S	ACCELERATION TIME
n019	60.0	S	DECELERATION TIME
n024	10.0	HZ	KEYPAD SPEED REFERENCE
n033	---	AMPS	MOTOR FULL LOAD AMPS- (MUST BE SET BY CUSTOMER)
n038	5	N/A	REMOTE/LOCAL (USED FOR NORMAL/TEST)
n039	9	N/A	TERMINAL S5 SELECTS AUTO/HAND SPEED REFERENCE SELECT
n040	21	N/A	PID CONTROL DISABLE
n043	1	N/A	TERMINALS F1 AND FV ANALOG INPUT SELECTION
n044	0	N/A	FOR OPTION P 0 TO 10VDC AUTO MODE SIGNAL, WITH CONTROL BOARD JUMPER J1 CUT
	1	N/A	4-20 MADC AUTO MODE SIGNAL
n055	1	N/A	MOMENTARY POWER LOSS RIDE THROUGH ENABLED
n056	20	%	SPEED SEARCH OPERATION LEVEL
n057	1.0	S	MINIMUM BASE BLOCK TIME
n058	25	%	V/F DURING SPEED SEARCH
n061	1	N/A	DRIVE FAULT RELAY DE-ENERGIZED DURING AUTO RESTART ATTEMPTS
n068	50	%	DC INJECTION BRAKING CURRENT LEVEL
n070	5.0	S	DC INJECTION BRAKING TIME AT START

CONTACT SEQUENCE CHART FOR S1

CONTACT	POSITION		MANUF. LOCATION /TYPE
	BYPASS	OFF/DRIVE	
1	X		1R0
2		X 1L0	1L0
3		X 2L0	2L0
4		X 3L0	3L0
5		X 4L0	4L0

CONTACT SEQUENCE CHART FOR S2

CONTACT	POSITION		MANUF. LOCATION /TYPE
	HAND	STOP/AUTO	
1	X		1R0
2		X 1L0	1L0
3	X		2R0
4		X 2L0	2L0
5	X		3R0

CONTACT SEQUENCE CHART FOR S3

CONTACT	POSITION		MANUF. LOCATION /TYPE
	TEST	NORMAL	
1		X	1R0
2	X		1L0
3	X		2R0
4	X		2L0
5	X		3R0

* SCHEMATIC SHOWS THIS POSITION.

CONTACTS 4 AND 5 PRESENT ONLY WITH OPTION P.

* SCHEMATIC SHOWS THIS POSITION.

