



- NOTES:
- CONNECTED TO THE CABINET. CUSTOMER TO CONNECT THE CABINET GROUND LUGS TO EARTH GROUND AND UTILITY GROUND.
 - INSULATED TWISTED SHIELDED WIRE IS REQUIRED. SHIELD TO CONNECT TO PROPER TERMINAL AS SHOWN. CONNECT THE SHIELD ONLY AT THIS END. STUB AND ISOLATE THE OTHER END. DO NOT RUN THESE WIRES IN THE SAME CONDUIT AS THE AC POWER AND THE AC CONTROL WIRES. KEEP ALL WIRING UNDER 50m IN LENGTH.
 - WITH A CONTROL TRANSFORMER, T1, POWER RATING 350VA OR GREATER, SECONDARY FUSE F6 IS ADDED.
 - WITHOUT THE INPUT CIRCUIT BREAKER OPTION PC, OR WHEN NOTED ON THE CABINET NAMEPLATE, BRANCH CIRCUIT PROTECTION MUST BE SUPPLIED BY THE INSTALLER.
 - CUSTOMER TO ADJUST THE THERMOSTAT ON THE SPACE HEATER HR1 FOR THE MINIMUM DESIRED TEMPERATURE INSIDE THE DRIVE CABINET. THIS SET TEMPERATURE IS NORMALLY SELECTED TO BE SLIGHTLY HIGHER THAN THE MINIMUM AMBIENT TEMPERATURE OF THE AIR SURROUNDING THE CABINET AND IS THE TEMPERATURE AT WHICH THE SPACE HEATER HR1 WILL SHUT OFF.
 - CONDUIT FITTINGS/HUBS SHALL COMPLY WITH THE STANDARD FOR CONDUIT, TUBING, AND CABLE FITTINGS, UL 514B' OR CONDUIT FITTINGS HAVING THE SAME ENVIRONMENTAL RATING AS THE ENCLOSURE SHALL BE USED.
 - TERMINALS p1 AND n1 ARE FOR MOMENTARY POWER LOSS RECOVERY UNIT. DO NOT CONNECT TO AC POWER SUPPLY.

- - INDICATES COMPONENTS NOT SUPPLIED BY YASKAWA
 * - INDICATES CUSTOMER WIRING
 ⚡ - CONNECTED TO THE CABINET OR PANEL

SEE DRAWING UDE00680 FOR DRIVE PARAMETERS.
 SEE DRAWING UDE00679 FOR CUSTOMER CONNECTIONS.

YASKAWA		DRAWN BY N. LAWS	DATE 03/09/21	TITLE SCHEMATIC DIAGRAM U1000 CONFIGURED TYPE 3R, 480V
		CHECKED BY K. MALUSIC	DATE 03/10/21	
		APPROVED BY R. JENSEN	DATE 03/11/21	
		ORIGINAL DESIGN N. LAWS	DATE 03/09/21	

REV.	DESCRIPTION	ECO #	DRAWN BY	DATE
01	ADDED CONTACT TO HOA	11412	N. LAWS	05/13/21
00	INITIAL RELEASE	---	N. LAWS	03/11/21



YASKAWA	DRAWN BY N. LAWS	DATE 03/09/21	TITLE SCHEMATIC DIAGRAM U1000 CONFIGURED TYPE 3R, 480V
	CHECKED BY K. MALUSIC	DATE 03/10/21	
THIS DOCUMENT AND INFORMATION CONTAINED HEREIN IS CONFIDENTIAL AND NOT BE COPIED OR DISCLOSED IN WHOLE OR IN PART WITHOUT THE EXPRESS WRITTEN CONSENT OF YASKAWA AMERICA, INC.		TECH R. JENSEN	DATE 03/11/21
		APPROVED BY N. LAWS	DATE 03/09/21
		SIZE D	REVISION 01
		PAGE 2 of 2	DRAWING # DS.U1E3.13